



DECLARATION OF CONFORMITY CE

According to the Directive of Products of Construction 89/106/CEE

The company CEMI-COLA PORT, S.L. with C.I.F. B - 97.414.411 and social home C/ Isaac Newton, 83 – Pol. Industrial Sepes – 46500 SAGUNTO – VALENCIA – SPAIN . Declares:

That the product TAPAJUNTAS JOINT MATERIAL (GROUT), cementitious adhesive jointing for the placement of bonded joints between tiles for wall or floor coverings in indoor and outdoor ceramic tiles, quarry tiles and similar finished products, manufactured in the center of production **CEMI-COLA PORT, S.L.** located in C/ Isaac Newton, 83 Pol. Ind. Sepes – SAGUNTO (Valencia) Spain, He has undergone the following rehearsals of type according to the requirements described in annexed ZA of the norm harmonized UNE-EN 13888 type CG2:

Characteristics of lists	Declared Values	Normative
Abrasion resistance	$\leq 1.000 \text{ mm}^3$	EN 12080-2
Resistance to the flexion c.n.	$\geq 3,5 \text{ N/mm}^2$	EN 12808-3
Resistance to the flexion after cliclos of ice - thaw	$\geq 3,5 \text{ N/mm}^2$	EN 12808-3
Resistance to the compression c.n.	$\geq 15 \text{ N/mm}^2$	EN 12808-3
Resistance to the compression after cliclos ice - thaw	$\geq 15 \text{ N/mm}^2$	EN 12808-3
Retraction	$\leq 2 \text{ mm/m}$	EN 12808-4
Water absorption after 30 m.	$\leq 2 \text{ g.}$	EN 12808-5
Water absorption after 4 h.	$\leq 5 \text{ g.}$	EN 12808-5

The rehearsals have been carried out by the Notified Organism N° 1170 (AIDICO).

It has also been implanted ex warehouse in the factory a production control that it completes the requirements of the norm UNE-EN 13888, for what all the relative dispositions have been applied to the evaluation of conformity described in the Annex ZA of the norm UNE-EN 13888, and so that it consists to the opportune effects, I sig the present in

Sagunto a 12 de Febrero de 2.020

Firmado:

RAFAEL GONZALEZ ANTA

Administrador Gerente


CEMI-COLA PORT, S.L.
C.I.F. B-97414411
C/. Isaac Newton, 83 - Pol. Ind. Sepes
46500 SAGUNTO (Valencia) España